

1/1 Monitoring Violations Annual Notice Template

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Monitoring Requirements Not Met for Taylorville Water

Our water system violated several drinking water standards over the past year. Even though these were not emergencies, as our customers, you have a right to know what happened and what we did to correct these situations.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During 1/1/2025 – 6/30/2025 we did not complete all monitoring and testing for lead and copper and therefore cannot be sure of the quality of our drinking water during that time.

What should I do?

There is nothing you need to do at this time.

The table below lists the contaminant(s) we did not properly test for during the last year, how often we are supposed to sample for lead and copper, how many samples we are supposed to take, how many samples we took, when samples should have been taken, and the date on which follow-up samples were (or will be) taken.

Contaminant	Required sampling frequency	Number of samples taken	When all samples should have been taken	When samples were or will be taken
Lead and copper	Every 6 months	44	60 every 6 months	Every 6 months

What happened? What is being done?

Despite multiple attempts at collecting the sample bottles we had 16 customers who failed to return the samples by the required time. Therefore we were in violation of not collecting the required 60 samples. We have added more people to the list of sample sites in the hopes of more cooperation in returning the samples to avoid violation.

For more information, please contact Josh Nicol at 217-287-1441 or at 2021 Lincoln Trail Taylorville IL 62568.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by Taylorville Water System
ID#0210600



Date distributed 9/22/2026